




# Columbia County 1,500 Gallon Grease Interceptor



MODEL: GI 1500/184

## PRODUCT INFORMATION

1,500 GALLON  
GREASE INTERCEPTOR

TANK= 18,000 #  
LID= 6,000 #  
DESIGN MAY VARY

## SPECIFICATIONS

MEETS ASTM C 1613

RATING: A-16 (H-20), ASSUME  
4" MAX EARTH COVER WITH 3"  
WATER TABLE BELOW GRADE

CONCRETE: 5,000 PSI @ 28 DAYS

STEEL REINFORCEMENT: MEETS  
ASTM A 615, PLACEMENT AS  
REQUIRED BY DESIGN

INLET & OUTLET BOOT MEETS  
ASTM C 923, ACCEPTS 4" & 6" PVC

BUTYL SEALANT: MEETS ASTM  
C 900, USED ON JOINTS

ACCESS OPENING SUITABLE FOR  
24" RISER AND/OR RING & COVER

INTERNAL PIPING BY OTHERS PER  
MUNICIPAL SPECS, POLYLOK  
PL 625 OUTLET FILTER & ALARM

BAFFLE CROSSOVERS TO BE  
(3) 4" PVC SLEEVES

COATED WITH CONSEAL CS-55  
INSIDE ONLY @ .0038" THICKNESS



## DRAWING INFORMATION

Drawn By: JJG  
Checked By: \_\_\_\_\_  
Revision: 1  
Date: 5/17/13

APPROVED BY: \_\_\_\_\_

print: \_\_\_\_\_

sign: \_\_\_\_\_

\*actual dimensions may vary slightly



**BARTOW  
PRECAST**

Scale: 1/4" = 1'

770.382.4462

sales@bartowprecast.com  
WWW.BARTOWPRECAST.COM